


# The Oregon Resilience Plan For Water & Wastewater Systems

House Committee on Veteran's Services and Emergency  
Preparedness  
and

Senate Committee on Veterans and Emergency Preparedness


June 20, 2013

Michael Stuhr, PE  
Chief Engineer  
Portland Water Bureau



# Water & Wastewater Resilience Plan

- ◆ Co-chairs: Mark Knudson (TVWD) and Mike Stuhr (PWB)
- ◆ Participants included representatives of ~ 45% of state
  - Portland, TVWD, Salem, Gresham, Eugene, Coos Bay, Bend, Pendleton
  - PSU, OSU, U of P, multiple consultants
- ◆ Four zones: Tsunami, Coast, Valley, East
- ◆ Approach
  - Identify event (maps)
  - Identify requirements & expectations
  - Identify performance of existing systems
  - Identify interdependencies
  - Identify “gaps” in systems performance
  - Generate recommendations



Cascadia Scenario Impact Zones

# Why Are Water/WasteWater (W/WW) Systems Vulnerable?


- ◆ Causes of damage
  - Tsunami (inundation)
  - Shaking (acceleration & velocity)
  - Permanent Ground Deformation (landslide, liquefaction, subsidence)
  - Cumulative effects
- ◆ System Vulnerability



The Great San Francisco EQ - 1906

# Why Are W/WW Systems Vulnerable?

- ◆ Large, complex systems, multiple failures
  - Source, treatment, pumping, storage, distribution



# Why Are W/WW Systems Vulnerable?

- ◆ Recovery highly dependent on other systems
  - Energy, transportation, people, equipment, financial



# Why Are W/WW Systems Vulnerable?

- ◆ Age, age, age (and condition)




# Why Are W/WW Systems Vulnerable?

- ◆ Pipelines vulnerable to structural damage



# Why Are W/WW Systems Vulnerable?

## ◆ Connections to structures



# Why Are W/WW Systems Vulnerable?


- ◆ Leaks, breaks & damage “after the meter”



# Resiliency Goals (Valley)

TARGET STATES OF RECOVERY: WATER & WASTE WATER SECTOR											
	Event occurs	0-24 hours	1-3 days	3-7 days	1 week-2 weeks	2 weeks-1 month	1 month - 3 month	3 month - 6 month	6 month -1 year	1 year-3 years	3+ years
<b>Domestic water supply</b>											
Potable water available at supply source. (WTP, wells, impoundment)		R	Y		G			X			
Main transmission facilities, pipes, pump stations, and reservoirs ("backbone") operational		G					X				
Water supply to critical facilities available.		Y	G				X				
Water for fire suppression - at key supply points.		G		X							
Water for fire suppression - at fire hydrants.				R	Y	G			X		
Water available at community distribution centers/points			Y	G	X						
Distribution system operational			R	Y	G				X		
<b>Wastewater systems</b>											
Threats to public health & safety controlled.			R	Y		G			X		
Raw sewage contained & routed away from population		R		Y			G		X		
Treatment plants operational to meet regulatory requirements					R			Y	G		X
Major trunk lines and pump stations operational					R		Y	G			X
Collection system operational							R	Y	G	X	
	Event occurs	0-24 hours	1-3 days	3-7 days	1 week-2 weeks	2 weeks-1 month	1 month - 3 month	3 month - 6 month	6 month -1 year	1 year-3 years	3+ years

# Evaluating Pipeline System Performance PGA, Landslides & Liquefaction



# Evaluating Pipeline System Performance

## System Specific Pipe Performance Estimates

- ◆ Estimate of main line leaks & breaks
  - "Seismic Fragility Formulations for Water Systems" American Lifeline Alliance, 2011
  - Based on empirical data from prior events
  - Input: Peak Ground Velocity, Permanent Ground Deformation, length of pipe, pipe material
  - Output: number of main leaks & breaks by pipe type
  
- ◆ Estimate of service line leaks & breaks
  - Based on anecdotal data for similar events
  - About 7% of all service lines fail (2% on utility side & 5% on customer side)


# Water Pipeline System Performance

Characteristic	Main Lines	Services
Length, Number	4,592 miles	385,600 connections
Number of Breaks	2,656	7,712 (utility side)
Number of Leaks	941	19,280 (customer side)
<b>Total Leaks &amp; Breaks</b>	<b>3,597</b>	<b>26,992</b>

- ◆ Unprecedented number of pipeline failures
  - Equivalent of ~16 years of breaks
- ◆ Will required ~3 months to repair
  - Assumes 3 hrs/break, 12hrs/d, 7d/wk, unlimited materials, equipment & transportation
  - Does not include repairs to customer-side

# Evaluating Facility Performance

## Performance of Reservoirs & Pump Stations



### ◆ Oregon Seismic Code

- Before 1960 = none
- 1960-70 = 0.06 g
- 1970-90 = 0.12 g
- 1990-2000 = ~ okay
- 2000 → = stringent

### ◆ Pump Stations


- 1/3 – major damage
- 1/3 – some damage
- 1/3 – minor affects

### ◆ Reservoirs

- 2/3 – major damage
- 1/6 – some damage
- 1/6 – minor damage


# Resiliency Goals

## Water & Wastewater System Performance



# Existing Condition

## Water & Wastewater System Performance



# Findings & Conclusions

- ◆ Significant gap between goals and existing state
- ◆ If CSZ EQ occurs today, it will result in dramatic change in “life as we know it” for W & WW
- ◆ Water generally better prepared than wastewater
- ◆ Eastern Oregon limited impacts
- ◆ Tsunami Areas take years to recover if ever
- ◆ Coast critically impacted; up to 3 years
- ◆ Extensive impacts to Valley; 6 months – 1 year

# Findings & Conclusions

- ◆ Resiliency upgrades will improve recovery times
- ◆ Focus on system “backbone” & water supply to critical facilities
- ◆ Costs will be significant but can be managed

# Recommendations

- ◆ Reset public expectations for recovery times
- ◆ Recommend Water/Wastewater utilities join ORWARN
- ◆ Require seismic response plans by all sectors
  - Include business continuity, employee & family support
- ◆ Require seismic assessments for all systems
  - Part of periodic update of master plans

# Recommendations

- ◆ OHA/DEQ require Water/Wastewater utilities to complete seismic risk assessment and mitigation plans as part of periodic updates to existing facility plans
- ◆ OHA/DEQ require Water/Wastewater utilities to include seismic design as part of system design
- ◆ OHA/DEQ work with Water/Wastewater utilities to define appropriate service levels, goals and expectations for post-EQ regulatory compliance

# Recommendations

- ◆ Encourage public health agencies, water and wastewater utilities to plan for significant water quality impacts to the Willamette and Columbia Rivers.

