

HOUSE AMENDMENTS TO HOUSE BILL 2180

By COMMITTEE ON ENERGY AND ENVIRONMENT

March 10

1 On page 1 of the printed bill, delete lines 8 through 20 and insert:

2 “(c) ‘Provisions for electrical service capacity’ means:

3 “(A)(i) Building electrical service, sized for the anticipated load of electric vehicle charging
4 stations, that has overcurrent devices necessary for electric vehicle charging stations or has ade-
5 quate space to add the overcurrent devices;

6 “(ii) Designated space within a building to add electrical service with capacity for electric ve-
7 hicle charging stations; or

8 “(iii) A designated location on building property, in or adjacent to a landscaped area, for in-
9 stalling remote service for electric vehicle charging stations; and

10 “(B) A conduit system installed from building electrical service, or from the dedicated spaces
11 or locations described in subparagraph (A) of this paragraph, to parking spaces that can support,
12 at a minimum, electrical wiring for installation of level 2 electric vehicle charging stations and, if
13 the conduit is for future installation of electric vehicle charging stations, that labels both ends of
14 the conduit to mark the conduit as provided for future electric vehicle charging stations.”.

15 On page 2, line 7, after “or” insert “process concerning”.

16 In line 8, delete “process”.

17
