

## SENATE AMENDMENTS TO SENATE BILL 338

By COMMITTEE ON LABOR AND BUSINESS

March 8

1 On page 1 of the printed bill, line 2, after the second semicolon delete the rest of the line and  
2 line 3 and insert “and declaring an emergency.”.

3 On page 5, delete lines 18 through 31 and insert:

4 “(a) Install, maintain, replace or repair electrical wiring and electrical products that convey  
5 energy from or operate on renewable electrical energy generation systems that use wind, solar en-  
6 ergy systems, microhydroelectricity, photovoltaic systems or fuel cells that do not exceed 50 kilo-  
7 watts AC, as measured by the sum of the manufacturer’s rated generating capacity; and

8 “(b) Make the following connections on renewable energy generation systems described in par-  
9 agraph (a) of this subsection:

10 “(A) All DC wiring and DC connections up to the load side of an inverter;

11 “(B) All AC wiring and AC connections to the termination of the final factory-provided inter-  
12 connecting cable that are made on the exterior of a structure, extending a maximum distance of 10  
13 feet from the renewable energy system, or a longer distance that the board specifies by rule, and  
14 extending not more than three feet within an accessible space of a structure, but not including  
15 connection to the structure’s wiring system; and

16 “(C) Connections to generators that are sized to facilitate the inverter in an off-grid system.

17 “**SECTION 2. This 2021 Act being necessary for the immediate preservation of the public**  
18 **peace, health and safety, an emergency is declared to exist, and this 2021 Act takes effect**  
19 **on its passage.”.**

20